



Certificate of Compliance

Project ID# 0003043185
Issued May 7, 2012

ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Less or Nonflammable liquid-Insulated Substation and Pad-Mounted Three Phase and Single Phase Transformers

Testing Category:

Electrical Equipment - Less or Non-Flammable Liquid Insulated Transformers

Three Phase Distribution Transformers, up to 5000 kVA , System voltages up to 72 kV, Cooling Class KNAN/KNAF, LV BIL \geq 3kVp, HV BIL \leq 350kVp. Transformers use Envirottemp $\text{\textcircled{R}}$ FR3 TM less flammable transformer insulation fluid.

Report Issued for:

Wilson Transformer Co Pty Ltd*
310 Springvale Road, (PO Box 5),
Glen Waverley, VIC 3150
Australia

* Equipment is manufacturing at the facility located at the Wilson Transformer Co Pty Ltd facility located on 10 Moloney Drive, Wodonga, VIC 3690, Australia

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Site Examination Report(s), of the following Standards and other documents:

<i>Approval Class Number</i>	<i>Date</i>	<i>Other Standards Organization, Designation</i>	<i>Date</i>
3990	June 1997	None	

Original Examination, Project Identification: 3043185

Report Issued: see below

Related Report: None

Subsequent Revisions: None

A handwritten signature in dark ink, appearing to read 'D. Waite', written over a horizontal line.

David Waite
Technical Team Manager
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

May 14, 2012
Date





Certificate of Compliance

Project ID# 0003043203
Issued May 7, 2012

ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Less or Nonflammable liquid-Insulated Substation and Pad-Mounted Three Phase and Single Phase Transformers

Testing Category:

Electrical Equipment - Less or Non-Flammable Liquid Insulated Transformers

Three Phase Power Transformers, up to 400 MVA , System voltages up to 400 kV, Cooling class KNAN/KNAF/KDAF, LV BIL \geq 20kVp, HV BIL \leq 1425kVp. Transformers use Envirotemp $\text{\textcircled{R}}$ FR3 TM less flammable transformer insulation fluid.

Report Issued for:

Wilson Transformer Co Pty Ltd
310 Springvale Road, (PO Box 5),
Glen Waverley, VIC 3150
Australia

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Site Examination Report(s), of the following Standards and other documents:

<i>Approval</i>	<i>Date</i>	<i>Other Standards</i>	<i>Date</i>
<i>Class Number</i>		<i>Organization, Designation</i>	
3990	June 1997	None	

Original Examination, Project Identification: 3043203

Report Issued: see below

Related Report: None

Subsequent Revisions: None

A handwritten signature in dark red ink, appearing to read 'D Waite', written over a horizontal line.

David Waite
Technical Team Manager
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

May 7, 2012
Date

